

CSU ENVIRONMENTAL REVIEW CHECKLIST

2-3-1-.25 PHYSICAL ENVIRONMENTAL REQUIREMENTS	Y	N	Comment
Bathrooms			
Ventilated			
Handicapped accessibility/grab bars			
1 shower per 8 individuals			
1 toilet and sink per 6 individuals			
Access to bathrooms not through another individual's bedroom			
Shower head recessed or non-weight bearing			
No weight bearing protrusions, over 30 lbs.			
Toilet flush-o-meter, no water tank or cover.			
Mirrors			
Polycarbonate mirror			
Fully secured			
Flush mounted			
Seclusion and Restraint Room			
Must be free of sharp edges/corners.			
Withstand physical abuse			
Up to 3 feet high around the room must be impermeable to body fluids.			
Where padded noncombustible material used.			
Minimum of 70 sq feet			
Ceiling must be at least 9 ft high.			
Any CSU with 36 beds or more must have two seclusion and restraint rooms			
S & R Bed			
Must be designed commercially for restraint.			
Must be bolted to the floor and without sharp edges.			
Must be impermeable to fluids.			
Must allow accessibility to lights, smoke detectors or items in the ceiling.			
Must be free of sharp edges/corners.			
Window			
Unbreakable			
Blind spots addressed.			
Fenced recreational area			
Enclosed with a minimum height of 6 feet.			
Privacy from public view.			
May be topped with a 45 degree inward slanting restraining wire using no sharp injurious material.			
Screening Area			
Adjacent to the waiting area			
One or more windows provide visual access to staff from a common area.			
Bedrooms			

Any furniture that is capable of barricading the door shall be secured to the wall			
No beds with springs, cranks, rails, wheels, rollaway, cots, bunks, stacked, hide-a-bed, and pull out couches Minimum of 60 sq ft per individual			
Textured windows for privacy, non – weight bearing curtain or blinds			
Additional Requirements			
Locked storage for valuable and belongings of all individuals.			
Laundry facilities provided for resident use.			
Entrance, exits and sidewalks free of impediments.			
1 operable non-pay phone.			
1 drinking fountain per CSU accessible to all residents.			
Hardware must be incapable of manipulation or removal.			
Lighting must be sufficient for reading.			
Lighting fixtures must be recessed or tamper proof (ex. lexan).			
Water temp maintained between 110-120 F degrees (43-48 C)			
Unbreakable mirrors.			
82-3-1-23 Environment of Care			
The ceilings and air distribution devices, light fixtures, sprinkler heads, and other apparatus shall be tamper-resistant.			
Blind spots addressed. unbreakable mirrors.			
Doors shall be locked from within and shall be capable of swinging outward.			
Electronic locks shall be equipped with a manual key override.			
Hardware must be incapable of manipulation or removal.			
Lighting must be sufficient for reading.			
Lighting fixtures must be recessed or tamper proof (ex. lexan).			
Water temp maintained between 110-120 F degrees (43-48 C)			
Unbreakable mirrors.			